

Table 9.32.3.5.
Principal Ventilation System Exhaust Fan Minimum Air-flow Rate
 Forming Part of Clause 9.32.3.5.(1)

Floor Area, m ²	Minimum Air-flow Rate, L/s				
	Number of Bedrooms				
	0-1	2-3	4-5	6-7	> 7
< 140	14	21	28	35	42
140-280	21	28	35	42	49
281-420	28	35	42	49	56
421-560	35	42	49	56	64
561-700	42	49	56	64	71
> 700	49	56	64	71	78

Notes to Table 9.32.3.5.

A bedroom is considered as a room with a window conforming to Article 9.9.10.1., a closet and an interior door.

Table 9.32.3.6.
Kitchen/Bathroom Exhaust Fan Minimum Air-flow Rate Forming
 Part of Sentence 9.32.3.6.(1)

Room	Minimum Exhaust Fan Air-flow Rate, L/s	
	Intermittent	Continuous
Kitchen	47	N/A
Bathroom	23	9

Table 9.32.3.8.(3)
Maximum Equivalent Duct Length⁽¹⁾, m Forming
part of Sentence 9.32.3.8.(3)

Flexible Duct						
Equivalent Diameter, mm (Cross Section Area for Rectangular Ducts, cm ²)	Fan Capacity, L/s					
	25	40	50	60	70	80
125 (123)	32	15	—	—	—	—
150 (177)	46	40	28	18	13	—
	46	46	46	46	46	24
175 (240)	46	46	46	46	46	46
200 (314)	46	46	46	46	46	46

Rigid Duct						
Equivalent Diameter, mm (Cross Section Area for Rectangular Ducts, cm ²)	Fan Capacity, L/s					
	25	40	50	60	70	80
100 (79)	32	15	—	—	—	—
125 (123)	46	40	28	18	13	—
	46	46	46	42	34	24
150 (177)	46	46	46	46	46	46
175 (240)	46	46	46	46	46	46