



NOTES:

1. SIZE CHAMBER FOR 0.25 sq m OF WATER SURFACE AREA PER 1 L/s OF 6-MONTH STORM DESIGN FLOW. HIGHER FLOWS TO BE RESTRICTED BY CONTROL ORIFICE AND BYPASSED.
2. HIGH FLOW BYPASS NOT REQUIRED IF WATER SURFACE AREA IN CHAMBER EXCEEDS 0.70 sq m PER 1 L/s OF 6-MONTH STORM DESIGN FLOW.