



NOTES:

1. REFER TO MMCD FOR DESCRIPTION OF MATERIALS.
2. MIN. 100mm DEPTH OF 19mm GRANULAR BASE UNDER CURBS.
3. SUBGRADE COMPACTION TO BE APPROVED BY CONTRACT ADMINISTRATOR.
4. INSTALL CURTAIN DRAINS AS DIRECTED BY CONTRACT ADMINISTRATOR.