



cover more than one (1) tent or structure. (*Non- certified Tarpaulins are covering multiple tents in multiple locations*)

- d. All flammable liquids, flammable or compressed gases, and any other flammable materials must be stored at least three (3) metres away from any tent or structure, and any refueling of heating, lighting, cooking or other appliances must be done at least three (3) metres away from any tent or structure.
- e. All open flame appliances must be used and stored downwind from, and at least three (3) metres away from any tent or structure, and must be fully extinguished when not in use.
- f. Portable generators and any other equipment capable of discharging carbon monoxide must be used and stored at least one (1) metre away from tents or structures, and must be positioned in such a manner as to prevent the accumulation of carbon monoxide in or near tents or structures.

### 3. Other

- a) No smoking in the Park.
- b) Tall grass that has been cut must be removed.
- c) Tents shall not be placed within (3) metres of a fence or structure.

### Corrective Measures

Please address all items **immediately**.

\_\_\_\_\_  
Brock Henson  
Saanich Fire Department  
Local Assistant to the Fire Commissioner

Date \_\_\_\_\_